# Plug-In Gait Full-Body

This tutorial describes how to implement the Golem/Plug-in Gait Upper Extremity model as implemented in Vicon (via Bodybuilder/PIG) in Visual3D. The Golem or Plug-in-Gait upper body model consists 9 segments:

- Pelvis
- Thorax
- Head
- Left/Right Upper Arms
- Left/Right Forearms
- Left/Right Hands

The Pelvis definition is not described in this tutorial, but can be found in the Lower Body Tutorial. The Clavicle segment's definitions are described in the Vicon documentation but are not used for kinetics/kinematics. They can only be tracked when using Inverse Kinematics and are therefore omitted from this model. Details about implementing this segment are provided in the Clavicle section of this tutorial.

The Plug-In Gait Full-Body model consists of the Plug-In Gait Upper Extremity model alongside the Plug-In Gait Lower Limb model. Complete the Lower Body Tutorial to create the lower extremity segments and produce the entire Full-Body model.

## Documentation Differences

The tutorial tries to follow Vicon's instructions as close as possible, but some modifications were required to implement the model in Visual3D. This means that results from Vicon and Visual3D may show some small differences. Some of the bigger differences are described below. At this time, no comparisons have been made between this model and the one provided by Vicon. The tutorial was not meant to be comprehensive and variations may exist between this version of the Golem model and the Vicon Golem model.

### Segment Origin

Vicon defines the origin of the segments at the distal end of the segment. By default, Visual3D defines the origin of the segments at the proximal end of the segment. This tutorial chose to define the origin at the proximal end of the segment, as this is more convenient in Visual3D, and will have no affect on the results.

### Segment Orientation

This tutorial uses the Visual3D default segment orientation. The default segment orientation for Visual3D is:

- X - ML (red)

- Y - AP (green)
- Z - Axial (bue)

If you review the Vicon documenation[1], the segment orientation and colors are different from those in Visual3D. Vicon's coordinate systems are:

- Y - ML (blue)
- X - AP (green)
- Z - Axial (red)

This means if you use the Visual3D segment orientation, when calculating joint angles, you will select an XYZ rotation sequence. This will result in joint angles provide a rotation about the mediolateral, AP, and then axial axes. This is consistent with Vicon's joint angle calculations - and with the biomechanics convention.

# Data Collection

## Marker Set

To complete this tutorial, you should use the PiG marker[2]. It will be easiest if you use the same naming convention. Please note that this is a minimal marker set, so if there is target drop out, or a target was not placed, most likely, you will not be able to use the data set. Please note this model is also very sensitive to the subject's posture during the static trial. When using this model, you should make sure that the subject is in a T-Pose during the static trial.

This image was adapted from the PiG Marker Set document [2]



### Subject Measurements

In addition to subject **height & mass**, there are 4 required bilateral anthroprometric measurements that need to be measured on the subject:

| Measurement | Description |
|---|---|
| Shoulder Offset | This is the vertical distance from the center of the glenohumeral joint to the marker on the acromion calivicular joint (RSHO & LSHO). Some researchers have used the (anterior/posterior girth)/2 to establish a guideline for the parameter. |
| Elbow Width | This is the distance between the medial and lateral epicondyles of the humerus. |
| Wrist Width | This is the distance between the ulnar and radial styloids. |
| Hand Thickness | This is the distance between the dorsal and palmar surfaces of the hand. |

## Create Segments

### Sample Files

Sample files can be downloaded here. The download contains two static trials:

1. Sub01_Static01.c3d can be used to follow this tutorial
2. Sub01_Walk01.c3d is a dynamic trial which can be associated with this static trial

The download also contains two CMO files:AltnerateDefinition.cmo is an example of the alternate definitions shown in the tutorial; and viconDefinition.cmo is an example of the Vicon definitions shown in the tutorial.

### Model Metrics

There are nine model metrics in this model which MUST be taken at the time of data collection. In some cases, Vicon requests the diameter, and in other cases, the radius is used. To simplify things, this tutorial will primarily the radius value. Many of the landmarks/segment definitions are based on these metrics so it is VERY important to create these metrics.

Model Metrics Explained

1. **Height** (m): The subject's height in meters\
2. **Mass** (kg): The subject's weight in kilograms
3. **MarkerRadius** (m): The marker radius is half the diameter of the motion capture markers used for data collection
4. **L/RShoulderRadius** (m): The vertical offset from the base of the acromion marker to shoulder joint center[1] (pg. 18).
5. **L/RElbowRadius** (m): Half the width of the elbow along flexion axis (roughly between the distal epicondyles of the humerus)[1] (pg. 18).
6. **L/RWristRadius** (m): Half the mediolateral thickness of the wrist at the position where the wrist marker bar is attached[1] (pg. 18). NOTE: The Vicon documentation states the A/P thickness, but the WRA/WRB targets should be placed on the thumb/pinkie side of the wrist[2] (pg. 2), which actually defines the mediolateral border of the wrist.

7. **L/RHandOffset** (m): The distance between the dorsum and palmar surfaces of the hand.

### Create Model Metrics

### 1. Create Subject Metrics:

1. Click **Subject Data/Metrics** button

    1. Select the *Mass* and click the **Modify Selected Item** button
    **Name:** *Mass*
    **Value or Expression:** *75 //*
    ***NOTE:*** *This value MUST be changed for each subject*

    - *Select the //Height* and click the **Modify Selected Item** button
    **Name**: *Height*
    **Value or Expression:** *1.8*
    **NOTE:** This value MUST be changed for each subject

    2. Click **Add New Item** button
    **Name:** *MarkerRadius*
    **Value or Expression:** *0.005*
    **NOTE:** This value MUST reflect the size of the markers used in YOUR lab

    3. **Name:** *LShoulderRadius*
    **Value or Expression:** *( 0.17*Distance(LSHO,RSHO) ) - MarkerRadius*
    Create the *RShoulderRadius*
    **NOTE:** The equation above is used instead of manually entering the manual measurements. This equation is from the RAB Model. Vicon's model requires the user manually collect these measurements. If using an explicit value, you MUST change this for each subject.

    4. **Name:** *LElbowRadius*
    **Value or Expression:** *0.06*
    Create the *RElbowRadius*
    **NOTE:** This value MUST be changed for each subject

    5. **Name:** *LWristRadius*
    **Value or Expression:** *( 0.5*DISTANCE(LWRA,LWRB) ) - MarkerRadius*
    Create the *RWristRadius*
    **NOTE:** The above equation only works if the mediolateral wrist targets are placed directly on the wrist. If the wrist targets are placed on a wand, you will need to explicitly specify the wrist radius. If using an explicit value, you MUST change this for each subject.

    6. **Name:** *LHandOffset*
    **Value or Expression:** *0.03*
    Create the *RHandOffset*
    **NOTE:** This value MUST be changed for each subject

## Head Segment

Prior to creating the head segment, 3 landmarks must be created:

1. Head_Front - the midpoint between the LBHD and RBHD
2. Head_Back - the midpoint between the LBHD and RBHD
3. Head_Right - the midpoint between the RFHD and RBHD

The origin is then defined at the Head_Front landmark. The AP axis is along the line from the Head_Front to Head_Back landmarks. The ML axis is defined using the Head_Right landmark. [1] pg.41

**NOTE:** The Head_Mid landmark is used as the distal end of the segment so that the segment geometry is created in the appropriate location.

### Head Landmarks




### 1. Create Head_Front:

1. Click **Landmarks** button
2. **Add New Landmark** button
3. Create Landmark: Head_Front

**Landmark Name:** *Head_Front*
**Define Orientation Using:**
**Starting Point:** *RFHD*
**Ending Point:** *LFHD*
Offset Using the Following **ML/AP/AXIAL** Offsets:
**AXIAL:** *0.5*
**Check:** *Offset by Percent (1.0 = 100%)*
**Check:** *Calibration Only Landmark*

---




### 2. Create Head_Back:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: Head_Back

**Landmark Name:** *Head_Back*
**Define Orientation Using:**
**Starting Point:** *RBHD*
**Ending Point:** *LBHD*
Offset Using the Following **ML/AP/AXIAL** Offsets:

**AXIAL:** *0.5*
**Check:** *Offset by Percent (1.0 = 100%)*
**Check:** *Calibration Only Landmark*

---




### 3. Create Head_Mid:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: Head_Mid

**Landmark Name:** *Head_Mid*
**Define Orientation Using:**
**Starting Point:** *Head_Front*
**Ending Point:** *Head_Back*
Offset Using the Following **ML/AP/AXIAL** Offsets:
**AXIAL:** *0.5*
**Check:** *Offset by Percent (1.0 = 100%)*
**Check:** *Calibration Only Landmark*

---




### 4. Create Head_Right:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: Head_Right

   **Landmark Name:** *Head_Right*
   **Define Orientation Using:**
   **Starting Point:** *RFHD*
   **Ending Point:** *RBHD*
   Offset Using the Following **ML/AP/AXIAL** Offsets:
   **AXIAL:** *0.5*
   **Check:** *Offset by Percent (1.0 = 100%)*
   **Check:** *Calibration Only Landmark*

---

### Head Definition




**1. Create Head Segment:**

1. In the **Segments** tab, select *Head* in the Segment Name box.
2. Click on the **Create Segment** button.
3. In the **Head** tab, enter these values:

   **Define Proximal Joint and Radius**
   **Lateral:** *None* **Joint:** *Head_Front* **Medial:** *None*
   **Radius:** *0.5*DISTANCE(RFHD,LFHD)*
   **Define Distal Joint and Radius**
   **Lateral:** *None* **Joint:** *Head_Mid* **Medial:** *None*
   **Radius:** *0.5*DISTANCE(RBHD,LBHD)*
   **Extra Target to Define Orientation**
   **Location:** *Medial* *Head_Right*
   **Select Tracking Targets:**
   *LBHD*, *LFHD*, *RBHD*, *RFHD*

4. Click on **Build Model.**
5. Click on **Close Tab** before proceeding.




### 2. Modify the Segment Coordinate System:

1. Define the Segment Orientation as:
   **A/P Axis:** *+Z*
   **Distal to Proximal:** *+Y*

---

### 3. Change the graphic:

**Model File:** *head_c7_top.v3g*

### 4. Rotate/Scale the Graphic Model:

1. Rotate:
   **Vertical Rotation:** *90*
   **Horizontal Rotation:** *0*
   **Clockwise Rotation:** *180*
2. Move:
   **Move Left/Right:** *0*
   **Move Back/Forward:** *55*
   **Move Up/Down:** *40*
3. Scale:
   **Scale Height:** *200*
   **Scale Width:** *200*
   **Scale Depth:** *200*

---

## Trunk

Prior to creating the trunk segment, 3 landmarks must be created:

1. Thorax_Prox - the midpoint between the CLAV and C7
2. Thorax_Dist - the midpoint between the STRN and T10
3. Thorax_AP - the midpoint between the CLAV and STRN

The origin is defined at the Thorax_Prox landmark (see NOTE below). The Axial (Z) axis is defined along the line from the Thorax_Prox to Thorax_Dist. The AP axis is defined by the Thorax_AP landmark.

**NOTE:** If you read the Vicon documentation, you will notice that the origin is located by the CLAV marker. In Visual3D, the segment geometry is defined along the long axis (in this case, the Z axis) - the long axis is defined along the line from the proximal to distal end. If the origin (proximal end) was defined at the CLAV marker, the center of mass for the trunk would be created anterior to the actual center of mass. For this reason, in the Visual3D representation, the origin is defined at the mid point between the CLAV and C7 targets. The orientation of the coordinate system is still defined the same, so the joint angles will not be affected by this change.

### Trunk Landmarks



### 1. Create Thorax_Prox:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: Thorax_Prox

**Landmark Name:** *Thorax_Prox*
**Define Orientation Using:**
**Starting Point:** *CLAV*
**Ending Point:** *C7*
Offset Using the Following **ML/AP/AXIAL** Offsets:
**AXIAL:** *0.5*
**Check:** *Offset by Percent (1.0 = 100%)*
**Check:** *Calibration Only Landmark*

---




### 2. Create Thorax_Dist:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: Thorax_Dist

**Landmark Name:** *Thorax_Dist*
**Define Orientation Using:**
**Starting Point:** *STRN*
**Ending Point:** *T10*
Offset Using the Following **ML/AP/AXIAL** Offsets:
**AXIAL:** *0.5*
**Check:** *Offset by Percent (1.0 = 100%)*
**Check:** *Calibration Only Landmark*

---




### 3. Create Thorax_AP:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: Thorax_AP

**Landmark Name:** *Thorax_AP*
**Define Orientation Using:**
**Starting Point:** *CLAV*
**Ending Point:** *STRN*
Offset Using the Following **ML/AP/AXIAL** Offsets:
**AXIAL:** *0.5*

**Check:** *Offset by Percent (1.0 = 100%)*
**Check:** *Calibration Only Landmark*

---




### Trunk Definition

### 1. Create Thorax/Ab Segment:

1. In the **Segments** tab, select *Thorax/Ab* in the Segment Name box.
2. Click on the **Create Segment** button.
3. In the **Thorax/Ab** tab, enter these values:

**Define Proximal Joint and Radius**
**Lateral:** *None* **Joint:** *Thorax_Prox* **Medial:** *None*
**Radius:** *0.5*DISTANCE(RSHO,LSHO)*
**Define Distal Joint and Radius**
**Lateral:** *None* **Joint:** *Thorax_Dist* **Medial:** *None*
**Radius:** *0.5*DISTANCE(RSHO,LSHO)*

**Extra Target to Define Orientation**
**Location:** *Anterior Thorax_AP*
**Select Tracking Targets:**
*C7*, *CLAV*, *STRN*, *T10*
**Depth (Meters):**
*0.5*DISTANCE(C7,CLAV)*

4. Click on **Build Model.**
5. Click on **Close Tab** before proceeding.

**2. Change the graphic:**

**Model File:** *thoraciccerviclewrtlumbar_z_up.v3g*

**3. Rotate/Scale the Graphic Model:**

1. Scale:
**Scale Height:** *120*
**Scale Width:** *120*
**Scale Depth:** *120*

---

## Clavicle

The clavicle is used as an intermediate segment in Vicon, and is not used for kinematics or kinetics, so there is no reason to create the clavicle in Visual3D when reproducing the Plug in Gait model.

However, if you still wish to create the Clavicle, instructions can be found here. If you are tracking using 6 DOF (the default), do NOT create the Clavicle, however if you are using Inverse Kinematics, it is ok to create the Clavicle.

---

## Upper Arm

Prior to creating the upper arm segment, 3 landmarks must be created:

1. L/RSJC - The shoulder joint center; there are two ways to define this (explained later)
2. L/RWJC - The wrist joint center; the midpoint between the L/RWRA and L/RWRB targets (the mediolateral wrist targets)
3. L/REJC - The elbow joint center; the L/RELB (lateral elbow target) target is created perpendicular to the plane defined by the SJC, WJC, and ELB. It is offset by the elbow radius measurement.

### Upper Arm Landmarks

These landmarks are required to create the Upper Arm segment, regardless if you use the Alternative Shoulder Definition (described above) or the Vicon Shoulder Definition.

In the instructions below, the definition of the shoulder joint center (SJC) is different from Vicon's shoulder definition. In the definition below, the SJC is created below the SHO target in the -Z direction of the trunk coordinate system. I recommend using this SJC definition since it is more straight forward (more intuitive) and leaves less room for error. If you would like to use the **Vicon Definition** for the shoulder joint center, you should follow the instructions for the Clavicle Landmarks. Regardless of whether you use the SJC method below, or the Vicon definition, you can use either the Vicon or Alternative definition for the Upper Arm Segment.




### 1. Create LSJC:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: LSJ
   **Landmark Name:** *LSJC*
   **Define Orientation Using:**
   **Starting Point:** *LSHO*
   **Existing Segment:** *Thorax/Ab*
   Offset Using the Following **ML/AP/AXIAL** Offsets:
   **ML:** *0.0*
   **AP:** *0.0*
   **AXIAL:** *- ( LShoulderRadius + MarkerRadius )*

**Do NOT Check:** *Offset by Percent (1.0 = 100%)*
**Check:** *Calibration Only Landmark*

### 2. Create RSJC:

1. When defining the right landmark, use same definitions as for the left landmark

---




### 3. Create LWJC:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: LWJC

**Landmark Name:** *LWJC*
**Define Orientation Using:**
  **Starting Point:** *LWRA*
  **Ending Point:** *LWRB*
Offset Using the Following **ML/AP/AXIAL** Offsets:
  **AXIAL:** *0.5*
**Check:** *Offset by Percent (1.0 = 100%)*
**Do NOT Check:** *Calibration Only Landmark*

### 4. Create RWJC

1. When defining the right landmark, use same definitions as for the left landmark

---




### 5. Create LEJC:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: LEJC
   **Landmark Name:** *LEJC*
   **Define Orientation Using:**
   **Starting Point:** *LELB*
   **Ending Point:** *LSJC*
   **Lateral Object:** *LWJC*
   Offset Using the Following **ML/AP/AXIAL** Offsets:
   **ML:** *- ( LElbowRadius + MarkerRadius )*
   **AP:** *0.0*
   **AXIAL:** *0.0*
   **Do NOT Check:** *Offset by Percent (1.0 = 100%)*
   **Check:** *Calibration Only Landmark*

### 6. Create REJC:

1. When defining the right landmark, use same definitions as for the left landmark

---

### Upper Arm Alternate Definition

The origin is defined at the SJC. The Axial axis is defined along the line from the SJC to EJC. The ML axis is along the line from the EJC to the ELB.




### 1. Create Left Upper Arm Segment:

1. In the **Segments** tab, select *Left Upper Arm* in the Segment Name box.
2. Click on the **Create Segment** button.
3. In the **Left Upper Arm** tab, enter these values:

**Define Proximal Joint and Radius**
**Lateral:** *None* **Joint:** *LSJC* **Medial:** *None*
**Radius:** *LShoulderRadius*

**Define Distal Joint and Radius**
**Lateral:** *None* **Joint:** *LEJC* **Medial:** *None*
**Radius:** *LElbowRadius*
**Extra Target to Define Orientation**
**Location:** *Lateral* *LELB*
**Select Tracking Targets:**
*LELB*, *LSHO*, *LUPA*

4. Click on **Build Model.**
5. Click on **Close Tab** before proceeding

---




## 2. Create Right Upper Arm Segment:

1. In the **Segments** tab, click the *Left Upper Arm* in the created segment list.
2. Click the **Copy & Reflect Selected Segment** button.
3. In the **Right Upper Arm** tab, make sure the right side values are displayed (the radius values are often not updated correctly - so make sure to update these for the right side).

### Upper Arm Vicon Definition

The origin is defined at the SJC. The Axial axis is defined along the line from the SJC to EJC. The ML axis is perpendicular to the plane defined by the SJC, EJC, and WJC.

**NOTE:** Since the SJC, EJC, and WJC landmarks are nearly colinear, creating the ML axis perpendicular to this plane can cause inconsistencies. For example, if you download the PiG_UE_Vicon.cmo file, you will notice the ML axis for the upper arm is pointing up. If you change the LElbowRadius to 0.05 (from 0.06), and hit Recalc, the ML axis will rotate 180 degrees. This seems to leave a lot to chance... You will also notice that the ML axis is not aligned with the ELB target. Typically, the flexion/extension axis is aligned with line between the elbow joint center and lateral epicondyle. For these reasons, I would recommend using the Alternative Definition for the Upper Arm.




### 1. Create Left Upper Arm Segment:

1. In the **Segments** tab, select *Left Upper Arm* in the Segment Name box.
2. Click on the **Create Segment** button.
3. In the **Left Upper Arm** tab, enter these values:

**Define Proximal Joint and Radius**
**Lateral:** *None* **Joint:** *LSJC* **Medial:** *None*
**Radius:** *LShoulderRadius*
**Define Distal Joint and Radius**
**Lateral:** *None* **Joint:** *LEJC* **Medial:** *None*
**Radius:** *LElbowRadius*
**Extra Target to Define Orientation**
**Location:** *Posterior* *LWJC*
**Select Tracking Targets:**
*LELB*, *LSHO*, *LUPA*

4. Click on **Build Model.**
5. Click on **Close Tab** before proceeding.

---




## 2. Create Right Upper Arm Segment:

1. In the **Segments** tab, click the *Left Upper Arm* in the created segment list.
2. Click the **Copy & Reflect Selected Segment** button.

3. In the **Right Upper Arm** tab, make sure the right side values are displayed (the radius values are often not updated correctly - so make sure to update these for the right side).

---

## Forearm

Two options to define the forearm are provided. One follows the Vicon Definition, and the other is an Alternate Definition, which is more consistent with biomechanics standards.

### Alternate Forearm Definition

The origin is defined at the elbow joint center. The Axial axis (Z) is defined along the line between the elbow joint center to the wrist joint center, and the mediolateral axis is aligned with that of the mediolateral wrist targets.

Since supination/pronation actually occurs by rotating the forearm, this motion should appear in the elbow joint angle. The alternate definition defines the forearm so that supination/pronation occurs at the elbow joint.

Another difference between the Vicon definition and the alternate definition is that the ELB target is placed on the humerus, so it shouldn't really be used to track the forearm. For this reason, in the alternate definition, a landmark at the distal end of the upper arm is used to track the forearm.

### Forearm Landmarks - Alternate Definition




### 1. Create LEJC_Track:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: LEJC_Track

**Landmark Name:** *LEJC_Track*
**Define Orientation Using:**
**Existing Segment:** *Left Upper Arm*
Offset Using the Following **ML/AP/AXIAL** Offsets:
**ML:** *0.0*
**AP:** *0.0*
**AXIAL:** *-1*
**Check:** *Offset by Percent (1.0 = 100%)*
**Do NOT Check:** *Calibration Only Landmark*

### 2. Create REJC_Offset:

1. When defining the right landmark, use same definitions as for the left landmark

---

### Forearm - Alternate Definition




**1. Create Left Forearm Segment:**

1. In the **Segments** tab, select *Left Forearm* in the Segment Name box.
2. Click on the **Create Segment** button.
3. In the **Left Forearm** tab, enter these values:

   **Define Proximal Joint and Radius**
   **Lateral:** *None* **Joint:** *LEJC* **Medial:** *None*
   **Radius:** *LElbowRadius*
   **Define Distal Joint and Radius**
   **Lateral:** *None* **Joint:** *LWJC* **Medial:** *None*
   **Radius:** *LWristRadius*
   **Extra Target to Define Orientation**
   **Location:** *Medial* *LWRB*
   **Select Tracking Targets:**
   *LEJC_Track*, *LFRA*, *LWRA*, *LWRB*

4. Click on **Build Model.**
5. Click on **Close Tab** before proceeding.
6. The image to the right (and all other images in this tutorial) show a mediolateral view of the

segment coordinate system after it has been modified.

---




### 2. Create Right Forearm Segment:

1. In the **Segments** tab, click the *Left Forearm* in the created segment list.
2. Click the **Copy & Reflect Selected Segment** button.
3. In the **Right Forearm** tab, make sure the right side values are displayed (the radius values are often not updated correctly - so make sure to update these for the right side).

---

### Vicon Forearm Definition

In the Vicon Definition, the Radius segment or Forearm segment is modeled as a hinge joint (see NOTE below).

The origin is defined at the elbow joint center. The Axial axis (Z) is defined along the line between the elbow joint center to the wrist joint center, and the mediolateral axis is aligned with that of the upper arm.[1] pg. 46

**NOTE:** Since supination/pronation occurs by rotating the forearm, this definition is atypical and is specific to the Plug-in Gait Model. The Plug-in Gait model is created so that supination/pronation will be seen in the wrist joint angle instead of the elbow joint angle.

### Forearm Landmarks - Vicon Definition




### 1. Create LFA_Offset:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: LFA_Offset
   *//*

   ***Landmark Name:*** *//LFA_Offset*
   **Define Orientation Using:**
   **Starting Point:** *LEJC*
   **Existing Segment:** *Left Upper Arm*
   Offset Using the Following **ML/AP/AXIAL** Offsets:
   **ML:** *0.05*
   **AP:** *0.0*
   **AXIAL:** *0.0*
   **Do NOT Check:** *Offset by Percent (1.0 = 100%)*

**Check:** *Calibration Only Landmark*

### 2. Create REJC_Offset:

1. When defining the right landmark, use same definitions as for the left landmark, **EXCEPT :** Specify the **ML:** offset as *-0.05*

---

### Forearm - Vicon Definition




### 1. Create Left Forearm Segment:

1. In the **Segments** tab, select *Left Forearm* in the Segment Name box.
2. Click on the **Create Segment** button.
3. In the **Left Forearm** tab, enter these values:

**Define Proximal Joint and Radius**
**Lateral:** *None* **Joint:** *LEJC* **Medial:** *None*

**Radius:** *LElbowRadius*
**Define Distal Joint and Radius**
**Lateral:** *None* **Joint:** *LWJC* **Medial:** *None*
**Radius:** *LWristRadius*\\ **Extra Target to Define Orientation**
**Location:** *Medial* *LFA_Offset*
**Select Tracking Targets:**
*LWJC*, *LELB*, *LFRA*

4. Click on **Build Model.**
5. Click on **Close Tab** before proceeding.
6. The image to the right (and all other images in this tutorial) show a mediolateral view of the segment coordinate system after it has been modified.

---




**2. Create Right Forearm Segment:**

1. In the **Segments** tab, click the *Left Forearm* in the created segment list.
2. Click the **Copy & Reflect Selected Segment** button.
3. In the **Right Forearm** tab, make sure the right side values are displayed (the radius values are often not updated correctly - so make sure to update these for the right side).

## Hand

The origin of the hand is at the midpoint between the wrist targets. The Axial (Z) axis is along the line from the wrist joint center to the hand joint center. The flexion/extension axis is defined along the line between the mediolateral wrist targets. [1] pg. 47

The definition of the hand joint center is not described as clearly as other joint centers... in this interpretation, the hand joint center is offset medially from the FIN target (which is on the dorsum of the hand at the head of the second metacarpal [2] pg. 3). This places the hand joint center closer to the middle of the hand (ex. by the third metacarpal).

### Hand Landmarks




### 1. Create LHJC:

1. Click **Landmarks** button
2. Click **Add New Landmark** button
3. Create Landmark: LHJC

**Landmark Name:** *LHJC*
**Define Orientation Using:**
**Starting Point:** *LFIN*
**Ending Point:** *LWRA*
**Lateral Object:** *LWJC*
Offset Using the Following **ML/AP/AXIAL** Offsets:
**ML:** *- ( LHandOffset + MarkerRadius )*
**AP:** *0.0*
**AXIAL:** *0.0*
**Do NOT Check:** *Offset by Percent (1.0 = 100%)*
**Check:** *Calibration Only Landmark*

### 2. Create RHJC:

1. When defining the right landmark, use same definitions as for the left landmark

---

### Hand Definition



### 1. Create Left Hand Segment:

1. In the **Segments** tab, select *Left Hand* in the Segment Name box.
2. Click on the **Create Segment** button.
3. In the **Left Hand** tab, enter these values:

   **Define Proximal Joint and Radius**
   **Lateral:** *None* **Joint:** *LWJC* **Medial:** *None*
   **Radius:** *LWristRadius*
   **Define Distal Joint and Radius**
   **Lateral:** *None* **Joint:** *LHJC* **Medial:** *None*
   **Radius:** *LHandOffset*
   **Extra Target to Define Orientation**
   **Location:** *Medial* *LWRB*
   **Select Tracking Targets:**
   *LFIN*, *LWRA*, *LWRB*

4. Click on **Build Model.**
5. Click on **Close Tab** before proceeding.
6. The image to the right (and all other images in this tutorial) show a mediolateral view of the segment coordinate system after it has been modified.




**2. Create Right Hand Segment:**

1. In the **Segments** tab, click the *Left Hand* in the created segment list.
2. Click the **Copy & Reflect Selected Segment** button.
3. In the **Right Hand** tab, make sure the right side values are displayed (the radius values are often not updated correctly - so make sure to update these for the right side).

---

# References

1. ↑ [1.0] [1.1] [1.2] [1.3] [1.4] [1.5] [1.6] [1.7] “Plug-In Gait” Web. 6 Jan 2016. http:%%//%%www.irc-web.co.jp/vicon_web/news_bn/PIGManualver1.pdf
2. ↑ [2.0] [2.1] [2.2] [2.3] [2.4] “Plug-In Gait Marker Placement” Web. 6 Jan 2016. http://www.idmil.org/mocap/Plug-in-Gait+Marker+Placement.pdf

From:
https://has-motion.com/wiki/ - **Wiki Documentation Site**

Permanent link:
**https://has-motion.com/wiki/doku.php?id=visual3d:tutorials:modeling:plug-in_gait_full-body&rev=1758563797**

Last update: **2025/09/22 17:56**